



Product certificate K101926/01

Issued 2019-07-15

Replaces

Page 1 of 2

Water meters

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

UAB Axioma Metering

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K618: "Water meters" dated: 15-01-2018

which covers the requirements of

EN-ISO 4064-1: 2017: "Water meters"

Ronald Karel
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

286180711

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273

P.O.Box 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

info@kiwa.nl

www.kiwa.nl

Company

UAB Axioma Metering

Veterinarių str. 52, Biruliškės

LT-54469 KAUNAS district

Lithuania

Tel. +370 37 360 234

metering@axioma.eu

www.axioma.eu



**Certification process
consists of initial and
regular assessment of:**

- quality system
- product

Water meters

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Qalcosonic W1

DN 15

- Ultrasonic water meter;
- PN 16;
- $Q_3 = 1,6\text{m}^3/\text{h}$, $250 \leq (Q_3/Q_1) \leq 315$;
- $Q_3 = 2,5\text{m}^3/\text{h}$, $250 \leq (Q_3/Q_1) \leq 400$;
- Overall Length: 80 -105 -110 -165- 170 mm.

DN 20

- Ultrasonic water meter;
- PN 16;
- $Q_3 = 2,5\text{m}^3/\text{h}$, $250 \leq (Q_3/Q_1) \leq 400$;
- $Q_3 = 4,0\text{m}^3/\text{h}$, $250 \leq (Q_3/Q_1) \leq 800$;
- Overall Length: 105 -110 -130 - 165- 190 mm.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" 

Place of the mark: on the meter or identification plate

Compulsory specifications:

- Unit of measurement (m^3);
- Numerical value of Q_3 ;
- MAP if where it differs from 1MPa;
- Direction of flow;
- MAT (where it differs from T30);
- Name or trademark of the manufacturer;
- Year of manufacture.

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to be applied in units are intended for drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 50°C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- UAB Axioma Metering
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.